

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity	4928.1 cd per klm.
(Luminaire orientation as tested.)	0.0 degrees vertical
	0.0 degrees horizontal

Beam Spread	At 10% of Imax	41.9V x 41.9H
	At 50% of Imax	17.6V x 17.6H
	At 90% of Imax	6.7V x 7.0H

Beam Flux	Total	938.6 lumens per klm.
	To 10% of Imax	598.5 lumens per klm.
	To 50% of Imax	272.4 lumens per klm.
	To 90% of Imax	57.7 lumens per klm.

Upward LOR	0.0 %
Downward LOR	93.9 %


Luminaire Efficiency (Light Output Ratio)	93.4 %
---	--------

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 01 September 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.265m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME: 96GRF1/515220	TYPE: 96GRF1/515220	WEIGHT: 1
SPEC.:	DIM.: F 120 x 90	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 5 Circle	Shielding Angle:



DATA OF LAMP		PHOTOMETRIC DATA	
MODEL	96GRF1/515220	Imax (cd)	1971
NOMINAL POWER (W)	5	AVAILABILITY (%)	59.3
RATED VOLTAGE (V)	230	Avai. FLUX (lm)	237.2
NOMINAL FLUX (lm)	400	LOR (%)	93.4
LAMPS INSIDE	1	TOTAL FLUX (lm)	373.5
TEST VOLTAGE (V)	230	θ @50% (H,V)	18,18DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM																UNIT:lm		Φ t	Φ a
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.04	0.00
90	0.00	0.00	0.00	0.01	0.01	0.03	0.04	0.04	0.05	0.05	0.04	0.03	0.02	0.01	0.01	0.00	0.00	0.00	0.36	0.00
80	0.00	0.00	0.01	0.03	0.05	0.09	0.11	0.14	0.15	0.15	0.14	0.12	0.08	0.05	0.02	0.01	0.00	0.00	1.15	0.00
70	0.00	0.00	0.02	0.05	0.11	0.18	0.26	0.34	0.39	0.38	0.33	0.25	0.16	0.09	0.05	0.02	0.00	0.00	2.64	0.00
60	0.00	0.01	0.03	0.09	0.18	0.34	0.53	0.73	0.84	0.82	0.68	0.51	0.32	0.16	0.08	0.03	0.01	0.00	5.36	0.00
50	0.00	0.01	0.04	0.12	0.30	0.58	0.97	1.44	1.77	1.72	1.34	0.89	0.56	0.28	0.12	0.04	0.01	0.00	10.2	0.00
40	0.00	0.01	0.05	0.16	0.44	0.92	1.74	2.93	3.96	3.86	2.73	1.57	0.81	0.41	0.16	0.05	0.01	0.00	19.8	0.00
30	0.00	0.01	0.06	0.20	0.58	1.31	2.86	5.87	10.1	9.69	5.41	2.56	1.13	0.51	0.20	0.07	0.01	0.00	40.6	24.8
20	0.00	0.01	0.07	0.23	0.66	1.61	3.98	10.8	35.6	31.9	9.12	3.44	1.38	0.58	0.23	0.07	0.01	0.00	99.7	87.4
10	0.00	0.01	0.07	0.24	0.65	1.63	4.10	11.3	38.8	35.1	9.44	3.51	1.40	0.60	0.23	0.07	0.01	0.00	107	95.0
0	0.00	0.01	0.06	0.21	0.56	1.34	3.06	6.36	11.3	10.7	5.64	2.69	1.18	0.54	0.21	0.07	0.01	0.00	44.0	29.0
-10	0.00	0.01	0.06	0.17	0.42	0.94	1.90	3.25	4.39	4.24	2.97	1.70	0.88	0.43	0.17	0.06	0.01	0.00	21.6	1.06
-20	0.00	0.01	0.05	0.13	0.30	0.59	1.05	1.57	1.91	1.86	1.47	0.99	0.61	0.29	0.12	0.04	0.01	0.00	11.0	0.00
-30	0.00	0.01	0.03	0.09	0.19	0.35	0.56	0.77	0.87	0.86	0.74	0.55	0.33	0.17	0.08	0.03	0.01	0.00	5.63	0.00
-40	0.00	0.00	0.02	0.06	0.12	0.18	0.26	0.34	0.40	0.40	0.35	0.26	0.17	0.10	0.05	0.02	0.00	0.00	2.72	0.00
-50	0.00	0.00	0.01	0.03	0.06	0.09	0.12	0.14	0.16	0.17	0.15	0.12	0.08	0.05	0.02	0.01	0.00	0.00	1.21	0.00
-60	0.00	0.00	0.00	0.01	0.02	0.03	0.04	0.05	0.05	0.05	0.05	0.04	0.03	0.02	0.01	0.00	0.00	0.00	0.39	0.00
-70	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00
-80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
HORIZONTAL (DEG)																				
Φ t	0.01	0.13	0.58	1.83	4.66	10.2	21.6	46.0	111	102	40.6	19.2	9.15	4.29	1.76	0.59	0.12	0.01	374	---
Φ a	0.00	0.00	0.00	0.00	0.00	0.00	1.36	29.5	96.3	87.4	22.8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	---	237

one-half-peak spread: U:9.4,D:8.3 , L:9.5,R:8.2

NEMA Beam Type: Type 3

C Range: 0 - 360DEG

C Interval: 10.0DEG

Test Speed: HIGH

Temperature:25.3°C

Operators:

Test Date:01 September 2022

γ Range: 0 - 90DEG

γ Interval: 2.5DEG

Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456


Humidity:65.0%

Test Distance:6.265m [K=1.0000]

Remarks:

ISOCANDELA DIAGRAM

NAME: 96GRF1/515220	TYPE: 96GRF1/515220	WEIGHT: 1
SPEC.:	DIM.: F 120 x 90	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 5 Circle	Shielding Angle:




C Range: 0 - 360DEG
 C Interval: 10.0DEG
 Test Speed: HIGH
 Temperature: 25.3°C
 Operators:
 Test Date: 01 September 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
 Humidity: 65.0%
 Test Distance: 6.265m [K=1.0000]
 Remarks:

ISOLUX DIAGRAM


NAME: 96GRF1/515220	TYPE: 96GRF1/515220	WEIGHT: 1
SPEC.:	DIM.: F 120 x 90	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 5 Circle	Shielding Angle:



C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 01 September 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.265m [K=1.0000]
Remarks:

Planar Illuminance Curve




C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 01 September 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.265m [K=1.0000]
Remarks:

AAI Figure

NAME: 96GRF1/515220	TYPE: 96GRF1/515220	WEIGHT: 1
SPEC.:	DIM.: F 120 x 90	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 5 Circle	Shielding Angle:



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG

C Interval: 10.0DEG

Test Speed: HIGH

Temperature:25.3°C

Operators:

Test Date:01 September 2022

γ Range: 0 - 90DEG

γ Interval: 2.5DEG

Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456

Humidity:65.0%

Test Distance:6.265m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: 96GRF1/515220	TYPE: 96GRF1/515220	WEIGHT: 1
SPEC.:	DIM.: F 120 x 90	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 5 Circle	Shielding Angle:

Table--1

UNIT: cd

H(DEC) V(DEC)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-90	0.02	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
-85	0.02	0.02	0.02	0.04	0.06	0.06	0.05	0.08	0.10	0.10	0.10	0.12	0.14	0.12	0.09	0.09	0.09	0.09	0.10
-80	0.02	0.03	0.04	0.07	0.11	0.12	0.13	0.19	0.24	0.26	0.29	0.38	0.46	0.52	0.57	0.60	0.61	0.58	0.54
-75	0.02	0.03	0.05	0.10	0.16	0.23	0.29	0.41	0.54	0.72	0.95	1.11	1.26	1.38	1.47	1.56	1.63	1.66	1.67
-70	0.02	0.04	0.08	0.14	0.26	0.40	0.55	0.80	1.12	1.55	1.89	2.17	2.38	2.60	2.78	2.96	3.11	3.29	3.43
-65	0.02	0.05	0.10	0.22	0.40	0.63	0.95	1.52	2.13	2.66	3.12	3.52	3.83	4.09	4.42	4.76	5.09	5.34	5.50
-60	0.02	0.05	0.13	0.29	0.57	0.99	1.62	2.41	3.17	3.90	4.59	5.27	5.76	6.21	6.73	7.25	7.65	8.02	8.29
-55	0.02	0.06	0.17	0.42	0.84	1.45	2.32	3.33	4.30	5.40	6.38	7.26	7.98	8.90	9.91	11.0	12.0	12.6	13.0
-50	0.02	0.08	0.21	0.55	1.12	1.93	3.03	4.25	5.53	6.93	8.26	9.62	11.4	13.6	15.9	18.2	19.2	19.8	20.3
-45	0.02	0.09	0.24	0.71	1.44	2.44	3.72	5.17	6.86	8.64	10.7	13.6	16.9	20.1	23.6	26.4	27.6	28.2	27.9
-40	0.02	0.09	0.29	0.88	1.74	2.94	4.35	6.12	8.26	11.0	14.5	18.5	22.8	27.8	32.2	35.2	38.1	40.1	41.3
-35	0.02	0.10	0.36	1.04	2.05	3.38	5.02	7.06	9.94	13.7	18.0	23.1	29.7	37.2	44.7	52.4	58.9	62.4	63.4
-30	0.02	0.11	0.43	1.19	2.31	3.77	5.61	8.05	11.8	16.5	21.4	29.4	39.2	50.9	64.7	76.5	86.9	92.4	94.7
-25	0.02	0.12	0.50	1.33	2.55	4.09	6.15	9.19	13.7	19.0	26.7	36.7	50.2	68.2	87.5	108	128	142	147
-20	0.02	0.12	0.55	1.45	2.75	4.39	6.64	10.3	15.8	22.6	31.6	44.1	64.1	86.0	116	155	190	215	222
-15	0.02	0.13	0.59	1.54	2.88	4.62	7.10	11.4	17.8	25.7	36.0	51.8	75.5	108	156	213	273	336	354
-10	0.02	0.13	0.63	1.60	2.96	4.79	7.44	12.3	19.4	28.1	39.8	59.5	86.4	130	194	277	440	740	873
-5	0.02	0.13	0.65	1.64	2.99	4.88	7.63	12.8	20.6	29.8	42.2	64.5	94.1	146	221	348	747	1436	1679
0	0.02	0.13	0.66	1.65	2.97	4.89	7.66	12.9	21.2	30.6	43.0	66.2	96.3	150	229	373	885	1698	1971
5	0.02	0.13	0.65	1.64	2.95	4.84	7.60	12.7	20.6	30.2	42.5	64.1	92.2	141	213	335	680	1281	1507
10	0.02	0.13	0.64	1.60	2.89	4.69	7.39	12.1	19.5	28.9	40.3	58.8	84.4	124	182	260	401	635	767
15	0.02	0.13	0.61	1.54	2.78	4.46	7.04	11.1	17.8	26.6	36.4	50.7	72.6	100	143	196	253	308	322
20	0.02	0.13	0.57	1.45	2.64	4.14	6.55	9.86	15.7	23.6	32.2	43.3	59.9	79.8	107	140	174	197	203
25	0.02	0.12	0.51	1.34	2.46	3.78	6.00	8.90	13.7	20.1	27.5	36.1	47.2	62.9	78.8	97.5	114	128	130
30	0.02	0.12	0.45	1.20	2.24	3.50	5.36	7.81	11.5	16.5	22.7	29.1	37.3	46.5	58.3	69.1	78.7	84.1	87.0
35	0.02	0.11	0.37	1.06	2.00	3.14	4.72	6.79	9.43	13.5	18.1	22.8	28.3	34.3	41.6	47.7	54.3	58.2	58.3
40	0.02	0.11	0.29	0.92	1.71	2.76	4.09	5.77	7.76	10.6	14.3	18.1	21.7	25.8	29.8	33.0	36.2	38.3	39.4
45	0.02	0.10	0.25	0.77	1.43	2.31	3.46	4.83	6.38	8.10	10.9	13.7	16.5	19.1	22.0	24.8	26.9	27.8	27.6
50	0.02	0.09	0.22	0.60	1.14	1.87	2.81	3.92	5.14	6.38	7.84	9.71	11.7	13.7	15.5	17.3	18.6	19.3	19.3
55	0.02	0.08	0.19	0.43	0.87	1.44	2.17	3.04	3.99	4.94	5.88	6.86	8.05	9.18	10.1	11.1	12.0	12.4	12.3
60	0.02	0.07	0.16	0.26	0.59	1.02	1.54	2.22	2.97	3.69	4.35	4.99	5.54	6.17	6.68	7.08	7.39	7.65	7.79
65	0.02	0.06	0.13	0.21	0.36	0.64	0.99	1.43	2.00	2.55	3.01	3.43	3.82	4.06	4.24	4.46	4.63	4.78	4.86
70	0.02	0.05	0.11	0.15	0.21	0.35	0.53	0.78	1.00	1.41	1.71	2.04	2.31	2.51	2.62	2.70	2.76	2.85	2.91
75	0.02	0.04	0.09	0.11	0.14	0.20	0.26	0.38	0.48	0.62	0.78	0.93	1.11	1.24	1.33	1.42	1.49	1.52	1.52
80	0.02	0.03	0.06	0.07	0.08	0.12	0.16	0.18	0.21	0.25	0.30	0.34	0.37	0.44	0.51	0.54	0.57	0.56	0.53
85	0.02	0.03	0.04	0.04	0.04	0.06	0.09	0.08	0.08	0.10	0.12	0.11	0.11	0.12	0.13	0.11	0.08	0.10	0.12
90	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02

C Range: 0 - 360DEG

C Interval: 10.0DEG

Test Speed: HIGH

Temperature:25.3°C

Operators:

Test Date:01 September 2022

γ Range: 0 - 90DEG

γ Interval: 2.5DEG

Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456

Humidity:65.0%

Test Distance:6.265m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: 96GRF1/515220	TYPE: 96GRF1/515220	WEIGHT: 1
SPEC.:	DIM.: F 120 x 90	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 5 Circle	Shielding Angle:

Table--2

UNIT: cd

H (DEG) V (DEG)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	
-90	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.02	0.01	0.01	0.02	0.02	0.02	0.02	0.02	0.02	
-85	0.12	0.15	0.14	0.12	0.13	0.14	0.12	0.09	0.10	0.10	0.08	0.05	0.06	0.06	0.04	0.03	0.03	0.02	
-80	0.54	0.53	0.49	0.46	0.43	0.39	0.33	0.25	0.23	0.22	0.17	0.13	0.12	0.11	0.07	0.04	0.04	0.02	
-75	1.64	1.57	1.49	1.37	1.23	1.11	0.98	0.85	0.70	0.56	0.40	0.24	0.20	0.16	0.11	0.06	0.04	0.02	
-70	3.41	3.33	3.17	2.94	2.59	2.23	1.94	1.65	1.37	1.09	0.83	0.56	0.36	0.23	0.14	0.08	0.05	0.02	
-65	5.46	5.33	5.15	4.79	4.25	3.70	3.12	2.65	2.22	1.80	1.37	0.98	0.61	0.36	0.20	0.11	0.06	0.02	
-60	8.24	8.03	7.66	7.09	6.32	5.49	4.65	3.86	3.18	2.64	2.09	1.47	0.96	0.53	0.25	0.13	0.07	0.02	
-55	13.0	12.5	11.6	10.3	9.03	7.69	6.52	5.38	4.31	3.55	2.83	2.09	1.37	0.77	0.37	0.17	0.08	0.02	
-50	20.0	19.3	18.1	15.9	13.5	11.2	9.00	7.23	5.87	4.64	3.65	2.74	1.82	1.02	0.48	0.20	0.09	0.02	
-45	27.4	26.5	24.7	22.5	19.6	16.6	12.7	9.71	7.55	6.01	4.58	3.43	2.32	1.34	0.62	0.23	0.11	0.02	
-40	39.9	37.7	34.6	30.9	27.1	22.8	18.2	13.4	9.81	7.43	5.60	4.16	2.86	1.66	0.76	0.27	0.12	0.02	
-35	61.0	55.8	48.4	41.7	35.3	30.0	24.7	18.4	13.1	9.12	6.69	4.85	3.36	2.03	0.89	0.33	0.12	0.02	
-30	88.3	81.0	70.0	58.4	45.7	36.3	30.0	23.0	16.7	11.3	7.91	5.56	3.88	2.38	1.04	0.38	0.13	0.02	
-25	138	119	99.0	79.5	60.9	44.9	34.9	27.3	19.6	13.5	9.14	6.28	4.34	2.67	1.21	0.42	0.14	0.02	
-20	207	176	139	104	77.5	56.5	39.8	30.6	22.7	15.5	10.4	6.96	4.72	2.91	1.34	0.46	0.15	0.02	
-15	319	250	188	135	95.8	66.8	45.7	33.4	24.9	17.2	11.6	7.55	5.01	3.10	1.45	0.48	0.15	0.02	
-10	670	382	240	167	111	76.2	51.2	36.2	26.7	18.6	12.4	7.99	5.22	3.23	1.54	0.50	0.16	0.02	
-5	1253	624	291	190	125	80.7	54.7	37.8	27.3	19.3	12.9	8.27	5.35	3.32	1.59	0.51	0.16	0.02	
0	1506	754	309	197	127	82.0	55.7	38.3	26.9	19.4	13.1	8.40	5.40	3.34	1.61	0.52	0.16	0.02	
5	1108	559	285	186	121	79.4	53.5	37.2	26.4	18.9	12.7	8.20	5.31	3.27	1.58	0.51	0.16	0.02	
10	582	355	234	162	109	73.9	49.7	34.7	25.2	17.9	12.0	7.85	5.13	3.15	1.51	0.50	0.16	0.02	
15	296	239	182	129	90.3	64.2	44.1	31.6	23.4	16.6	11.0	7.37	4.86	2.97	1.42	0.48	0.15	0.02	
20	193	167	129	97.5	73.1	52.1	37.0	28.4	21.0	15.0	9.87	6.78	4.49	2.74	1.31	0.45	0.15	0.02	
25	125	108	90.3	73.0	55.6	41.2	31.5	25.2	18.5	13.1	8.82	6.11	4.03	2.47	1.17	0.42	0.14	0.02	
30	81.5	73.3	64.0	52.2	41.4	32.6	27.2	21.6	15.6	11.0	7.59	5.38	3.58	2.17	1.02	0.37	0.14	0.02	
35	55.9	51.0	44.0	37.8	31.0	26.7	22.5	17.4	12.4	8.96	6.46	4.60	3.08	1.88	0.87	0.33	0.13	0.02	
40	38.4	35.6	32.4	28.1	24.4	21.2	17.7	13.5	9.60	7.24	5.34	3.79	2.62	1.56	0.74	0.27	0.12	0.02	
45	26.7	25.0	22.3	20.4	18.4	15.5	12.6	9.42	7.46	5.66	4.29	3.12	2.16	1.27	0.59	0.24	0.11	0.02	
50	18.7	17.8	16.6	15.1	13.1	10.9	8.74	7.13	5.73	4.42	3.37	2.51	1.71	0.99	0.46	0.21	0.10	0.02	
55	12.3	11.9	11.1	9.92	8.80	7.52	6.36	5.33	4.28	3.38	2.61	1.94	1.29	0.73	0.35	0.18	0.09	0.02	
60	7.75	7.58	7.26	6.74	6.12	5.40	4.62	3.83	3.13	2.52	1.93	1.37	0.90	0.48	0.23	0.15	0.08	0.02	
65	4.99	5.00	4.81	4.54	4.16	3.70	3.15	2.64	2.16	1.68	1.27	0.90	0.56	0.30	0.19	0.13	0.07	0.02	
70	3.00	3.04	2.98	2.84	2.58	2.27	1.89	1.54	1.25	0.96	0.74	0.52	0.31	0.18	0.14	0.11	0.06	0.02	
75	1.53	1.52	1.44	1.31	1.15	0.99	0.85	0.73	0.59	0.46	0.35	0.22	0.17	0.13	0.11	0.08	0.05	0.02	
80	0.50	0.47	0.46	0.44	0.39	0.34	0.30	0.26	0.21	0.18	0.16	0.14	0.11	0.08	0.07	0.06	0.04	0.02	
85	0.12	0.13	0.14	0.15	0.13	0.11	0.11	0.12	0.09	0.07	0.08	0.08	0.06	0.04	0.04	0.04	0.03	0.02	
90	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	

C Range: 0 - 360DEG

C Interval: 10.0DEG

Test Speed: HIGH

Temperature:25.3°C

Operators:

Test Date:01 September 2022

γ Range: 0 - 90DEG

γ Interval: 2.5DEG

Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456

Humidity:65.0%

Test Distance:6.265m [K=1.0000]

Remarks: